



70 CHESTNUT STREET
LEWISTOWN, PA 17044

PHONE: 717 248-0165
FAX: 717 248-0167
www.lewistownwater.com

SERVICE LINE SPECIFICATIONS

- ✓ TRENCH DEPTH = MIN 4'
- ✓ MIN 3/4" K-COPPER
- ✓ MIN 3/4" BLUE POLYETHYLENE FLEXIBLE PIPE 200 PSI COPPER TUBING SIZE - CTS,
SDR 9, AWWA C-901 FOR POTABLE WATER
 - COPPER TRACE WIRE
 - TRACE WIRE CLAMPED TO RISER
 - COUPLING INSERTS
- ✓ COMPRESSION COUPLINGS
- ✓ BRASS OR COPPER FITTINGS
- ✓ BEDDING OF SERVICE LINE – TOP SOIL, CLAY, SAND, OR FINE GRAVEL
- ✓ NO OTHER UTILITY, SANITARY SEWER, ETC. WITHIN 3' OF WATER PIPE DITCH

CALL FOR INSPECTION APPOINTMENT PRIOR TO CLOSING TRENCH

METER WILL BE INSTALLED AND WATER SERVICE WILL BECOME ACTIVE UPON APPLICANTS REQUEST